

Institutional Needs

The water requirements for institutional should be provided in addition to the provisions indicated in (a) above, where required, if they are of considerable magnitude and not covered in the provisions already made. The Individual requirements would be as follows:

Sl. No.	Institutions	Liters per head per day
1.	Hospital (including laundry)	
.	(a) No. of beds exceeding 100	450 (per bed)
	(b) No. of beds not exceeding 100	340 (per bed)
2.	Hotels	180 (per bed)
3.	Hostels	135
4.	Nurses' homes and medical quarters	135
5.	Boarding schools / colleges	135
6.	Restaurants	70 (per seat)
7.	Air ports and sea ports	70
8.	Junction Stations and intermediate stations where mail or express stoppage (both railways and bus stations) is provided	70
9.	Terminal stations	45
10.	Intermediate stations (excluding mail and express stops	45 (could be reduced to 25 where bathing facilities are not provided)
11.	Day schools / colleges	45
12.	Offices	45
13.	Factories	45 (could reduced to 30 where no bathrooms are provided)
14.	Cinema, concert halls and theatre	15